

LEAD and COPPER 90th PERCENTILE RESULTS

(Keep this form until you receive your sample results in the mail)

This form is for your own use- keep on file.
You do not have to submit this form to the State.

System Name: Middle Georgia State University

WSID #: 02300.3 County: Bleckley

Reporting Period: June 2016

How to determine the 90th Percentile Level

- 1) Place all test results in order - from the lowest result to the highest in the table below.
- 2) Note which samples are in the shaded area. These samples represent the 90th percentile for your system. (The 90th percentile is determined by multiplying the total number of samples taken by 0.9. For example, if you took 20 samples, $20 \times 0.9 = 18$. Therefore, the 18th sample is your 90th percentile.

		Lead				Copper			
1	0	11	2.2	Lowest Result	1	78	11	250	
2	0	12	2.2		2	95	12	250	
3	0	13	2.5		3	96	13	270	
4	0	14	2.7		4	100	14	270	
5	0	15	3.7		5	130	15	280	
6	1.2	16	3.9		6	170	16	430	
7	1.3	17	4.2		7	180	17	470	
8	1.6	18	5.1		8	230	18	480	
9	1.6	19	8.5		9	240	19	550	
10	1.9	20	8.7		Highest Result	10	240	20	1100

Please enter results here:

Lead 90th Percentile: 5.1 ppb (ug/L) Copper 90th Percentile: 480 ppb (ug/L)

The "action level" for LEAD is 15 ppb and the "action level" for COPPER is 1300 ppb. If your 90th% results for LEAD and/or COPPER exceed the action levels listed here,

you must notify the State of the exceedence.

The State/EPD will instruct you in regards to follow-up requirements that must be met.
Call 404-656-5660 and ask for Tamara Frank or Dominique Pate.

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:14 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ15994 System: middle georgia state university WSID: 0230003 Site Number: 001	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	250	ug/L	SAM	7/5/2016
Lead	01051	2.2	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:58 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ15995 System: middle georgia state university WSID: 0230003 Site Number: 002	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	78	ug/L	SAM	7/5/2016
Lead	01051	2.5	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440
 Lead and Copper Sample Analysis Report**

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:01 PM Sample Collector: K. EDENFIELD
Sample ID: AJ15996 System: middle georgia state university WSID: 0230003 Site Number: 003	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	470	ug/L	SAM	7/5/2016
Lead	01051	0	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:05 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ15997 System: middle georgia state university WSID: 0230003 Site Number: 004	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	250	ug/L	SAM	7/5/2016
Lead	01051	3.9	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION
SAFE DRINKING WATER REPORT**

5804 Peachtree Corners East, Norcross, GA 30092-3403
(678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:55 PM Sample Collector: K. EDENFIELD
Sample ID: AJ15998 System: middle georgia state university WSID: 0230003 Site Number: 005	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	1100	ug/L	SAM	7/5/2016
Lead	01051	8.7	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:07 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ15999 System: middle georgia state university WSID: 0230003 Site Number: 006	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	270	ug/L	SAM	7/5/2016
Lead	01051	1.6	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION
SAFE DRINKING WATER REPORT**

5804 Peachtree Corners East, Norcross, GA 30092-3403
(678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:10 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16000 System: middle georgia state university WSID: 0230003 Site Number: 007	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	240	ug/L	SAM	7/5/2016
Lead	01051	8.5	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/28/2016 Time Collected: 1:17 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ16001 System: middle georgia state university WSID: 0230003 Site Number: 008	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	180	ug/L	SAM	7/5/2016
Lead	01051	0	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:25 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16002 System: middle georgia state university WSID: 0230003 Site Number: 009	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	100	ug/L	SAM	7/5/2016
Lead	01051	0	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION
SAFE DRINKING WATER REPORT**
5804 Peachtree Corners East, Norcross, GA 30092-3403
(678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:23 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ16003 System: middle georgia state university WSID: 0230003 Site Number: 010	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	270	ug/L	SAM	7/5/2016
Lead	01051	0	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:19 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16004 System: middle georgia state university WSID: 0230003 Site Number: 011	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	96	ug/L	SAM	7/5/2016
Lead	01051	1.2	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:17 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ16005 System: middle georgia state university WSID: 0230003 Site Number: 012	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	430	ug/L	SAM	7/5/2016
Lead	01051	1.3	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440
 Lead and Copper Sample Analysis Report**

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:52 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ16006 System: middle georgia state university WSID: 0230003 Site Number: 013	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	240	ug/L	SAM	7/5/2016
Lead	01051	4.2	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION
SAFE DRINKING WATER REPORT**

5804 Peachtree Corners East, Norcross, GA 30092-3403
(678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:46 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16007 System: middle georgia state university WSID: 0230003 Site Number: 014	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	130	ug/L	SAM	7/5/2016
Lead	01051	1.6	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:35 PM Sample Collector: K. EDENFIELD Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016
Sample ID: AJ16008 System: middle georgia state university WSID: 0230003 Site Number: 015	

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	480	ug/L	SAM	7/5/2016
Lead	01051	1.9	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:50 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16009 System: middle georgia state university WSID: 0230003 Site Number: 016	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	280	ug/L	SAM	7/5/2016
Lead	01051	5.1	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:41 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16010 System: middle georgia state university WSID: 0230003 Site Number: 017	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	95	ug/L	SAM	7/5/2016
Lead	01051	3.7	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:37 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16011 System: middle georgia state university WSID: 0230003 Site Number: 018	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	230	ug/L	SAM	7/5/2016
Lead	01051	2.2	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT**
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 1:43 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16012 System: middle georgia state university WSID: 0230003 Site Number: 019	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	170	ug/L	SAM	7/5/2016
Lead	01051	2.7	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in your home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter	Laboratory Contact: Shene Jones (678) 248-7440
------------------------	--

**GEORGIA DEPARTMENT OF NATURAL RESOURCES
 ENVIRONMENTAL PROTECTION DIVISION
 SAFE DRINKING WATER REPORT
 5804 Peachtree Corners East, Norcross, GA 30092-3403
 (678) 248-7440**

Lead and Copper Sample Analysis Report

TO: Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014	Date Collected: 6/27/2016 Time Collected: 2:31 PM Sample Collector: K. EDENFIELD
Sample ID: AJ16013 System: middle georgia state university WSID: 0230003 Site Number: 020	Received By: DMV Date Received: 6/30/2016 Reporting Date: 7/11/2016

ANALYTE	PARAMETER CODE	RESULT	UNITS	ANALYST	ANALYSIS DATE
Copper	01042	550	ug/L	SAM	7/5/2016
Lead	01051	0	ug/L	SAM	7/5/2016

Thank you for participating in the implementation of the "Lead and Copper Rule" as required by the US Environmental Protection Agency. The water sample you collected from your house has been analyzed for lead and copper content; the results are given above.

Lead and copper may be found in household plumbing fixtures such as service lines, pipes, solders and fluxes, and brass and bronze fixtures. Lead is found throughout the environment in the air, soil, water, and household dust, and in consumer products such as food, lead-based paint, pottery porcelain and pewter. Lead and copper enter drinking water primarily as a result of the corrosion, or wearing away of materials containing these metals. Lead can pose a significant risk to your health if too much of it enters your body. The greatest risk is to young children and pregnant women. The US EPA has established an "action level" of 15 ug/l for lead and 1300 ug/l for copper. If concentrations measured in your household water exceed these "action levels", you can minimize your exposure by:

- * "flushing" the cold water faucet until the water becomes as cold as it will get; this removes the water that has stagnated in you home plumbing over several hours;
- * using cold water for drinking or cooking;
- * not cooking with or consuming water from the hot water faucet;
- * not using hot water for making baby formula;
- * using only "lead-free" solder, fluxes, and materials in new household plumbing and repairs.

For more information on reducing lead/copper exposure around your home, the health effects and primary sources of these contaminants, please visit the EPA's website at WWW.EPA.GOV/LEAD, call the National Lead Information Center at 1-800-424-LEAD, or contact your health care provider.

For more information contact your water supplier:

Mr. KYLE EDENFIELD 1100 SECOND STREET SE COCHRAN, GA 31014

For other questions Contact EPD Drinking Water Program (404) 656-5660

ug/L: micrograms/liter

Laboratory Contact:

Shene Jones (678) 248-7440

FINAL TARGETED SAMPLE SITES

Name Of Public Water System: Middle Georgia State University

Please mail the sample kit to the following address:

System ID#: GA 0230003

NOTES AND CHART CODES:

EPD Laboratories
5804 Peachtree Corners East
Norcross GA 30092-3403

Type of Structure

SFR Single Family Residences
MFR Multi-family Residences
BLDG Public Buildings

LSL (Lead Service Lines)

YES = Lead service lines present
NO = No lead service lines present

Home Plumbing Material

A: Material other than Lead or Copper
B: Lead interior lines
C: Lead or Copper solder installed 1/1/83-6/19/08
D: Lead or Copper solder installed before 1983
E: Lead piping

Site Number	Type of Structure	Location or address	Contact Person		LSL	Home Plumbing Material	Selected		Received Training Material (Y/N)
			Last Name, First Name	Phone			Routine	Optional	
1	BLDG	Sanford Hall	Edenfield, Kyle	478 934 3000	NO	D	X		Y
2	BLDG	Browning Memorial Hall	Edenfield, Kyle	"	NO	D	X		Y
3	BLDG	Roberts Library	Edenfield, Kyle	"	NO	D	X		Y
4	BLDG	Russell Hall	Edenfield, Kyle	"	NO	D	X		Y
5	BLDG	Dillard Hall	Edenfield, Kyle	"	NO	D	X		Y
6	BLDG	Harris Hall	Edenfield, Kyle	"	NO	C	X		Y
7	BLDG	Talmadge Hall	Edenfield, Kyle	"	NO	C	X		Y
8	BLDG	Peacock Hall	Edenfield, Kyle	"	NO	D	X		Y
9	BLDG	Walker Hall	Edenfield, Kyle	"	NO	D	X		Y
10	BLDG	Wiggs Hall	Edenfield, Kyle	"	NO	D	X		Y
11	BLDG	Jackson Hall	Edenfield, Kyle	"	NO	D	X		Y
12	BLDG	Ebenezer Hall	Edenfield, Kyle	"	NO	D	X		Y
13	BLDG	Grace Hall	Edenfield, Kyle	"	NO	D	X		Y
14	BLDG	Warrior Hall ^(Korshis)	Edenfield, Kyle	"	NO	C	X		Y

