

## GA EPD LCRR Service Line Inventory (SLI) Spreadsheet

Water System Name: Middle Georgia State University- Cochran Campus  
 Water System ID#: GA  
 Water System Type: CWS  
 Initial Inventory Submission Date: 10/16/2024

\*Information in the boxes below will autofill as the GA Detailed SL Inventory worksheet is completed\*

<b>33</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>33</b>
-----------	----------	----------	----------	-----------

**Total Number of Service Lines**     
 **Number of Lead Service Lines**     
 **Number of Galvanized Requiring Replacement Service Lines**     
 **Number of Lead Status Unknown Service Lines**     
 **Number of Non-Lead Service Lines**

Location Information							Ownership				
<i>Water systems must track addresses of all service lines in their internal inventory and in the inventory submitted to the GA EPD.</i>							<i>Water Systems must identify the service line material of each portion of a service line.</i>	<i>The service line classification table can be referenced under the "Classifying SLs" worksheet.</i>	<i>If known, select the specific service line material from the dropdown bar.</i>	<i>Additional information water systems want to note pertaining to the service line material.  For reference by the water system. (e.g. verification date if applicable)</i>	
Unique Service Line ID	Street Address 1 *Required*	Street Address 2	City *Required*	State *Required*	Zip *Required*	Other Location Identifier *Required if Street Address is not used for the publicly accessible inventory*	Service Line Ownership Type *Required*	Water System-Owned Portion Service Line Material Classification *Required*	Water System-Owned Portion Specific Service Line Material	Water System-Owned Portion Service Line Material Additional Information	
	1100 SE 2ND ST	BLDG 146	COCHRAN	GA	31014	GATEWAY DORMITORY	Split Ownership	Non-Lead	Other		
	552 FRANK COOK RD	BLDG 145	COCHRAN	GA	31014	WELCH HALL	Split Ownership	Non-Lead	Other		
	136 FRANK COOK RD	BLDG 147	COCHRAN	GA	31014	ANDERSON HALL	Split Ownership	Non-Lead	Other		
	178 COLLEGE ST	BLDG 405	COCHRAN	GA	31014	KNIGHTS HALL	Split Ownership	Non-Lead	Other		
	110 LAKESIDE DR	BLDG 148	COCHRAN	GA	31014	REGENTS DORMITORY	Split Ownership	Non-Lead	Other		
	ADMISSIONS AND WELCOME CENTER	BLDG 149	COCHRAN	GA	31014	ADMISSIONS AND WELCOME CENTER	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	POPE HOUSE	BLDG 273	COCHRAN	GA	31014	POPE HOUSE	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	SE 3RD ST	BLDG 274	COCHRAN	GA	31014	DILLARD HALL	Split Ownership	Non-Lead	Other		
	SARAH ST	BLDG 50	COCHRAN	GA	31014	DILLARD HALL	Split Ownership	Non-Lead	Other		
	1100 SE 2ND ST	BLDG 30	COCHRAN	GA	31014	ROBERTS LIBRARY	Split Ownership	Non-Lead	Other		
	SE 2ND ST	BLDG 40	COCHRAN	GA	31014	RUSSELL FINE ARTS HALL	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	SARAH ST	BLDG 10	COCHRAN	GA	31014	SANFORD HALL	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	SARAH ST	BLDG 20	COCHRAN	GA	31014	MEMORIAL HALL	Split Ownership	Non-Lead	Other		
	SARAH ST	BLDG 140	COCHRAN	GA	31014	GRACE HALL	Split Ownership	Non-Lead	Ductile Iron		
	COLLEGE ST	BLDG 130	COCHRAN	GA	31014	EBENEZER HALL	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	COLLEGE ST	BLDGS 120, 110, & 100	COCHRAN	GA	31014	JACKSON & WIGGS OFFICE BLDG & WALKER HALL	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron	SERVICE LINE >2" (3" DIAMETER)	
	COLLEGE ST	BLDG 90	COCHRAN	GA	31014	PEACOCK OFFICE BLDG	Split Ownership	Non-Lead	Other		
	COLLEGE ST	BLDG 80	COCHRAN	GA	31014	BROWNING DORMITORY	Split Ownership	Non-Lead	PVC		
	100 COLLEGE ST		COCHRAN	GA	31014	MGSU POLICE DEPARTMENT	Split Ownership	Non-Lead	Copper		
	COLLEGE ST	BLDG 160	COCHRAN	GA	31014	ALDERMAN COMMUNITY HALL	Split Ownership	Non-Lead	Copper		
	COLLEGE ST	BLDG 161	COCHRAN	GA	31014	WAREHOUSE NO. 2	Split Ownership	(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		
	COLLEGE ST	BLDG 162	COCHRAN	GA	31014	CHILLER PLANT	Split Ownership	Non-Lead	Other		
	148 COLLEGE ST	BLDG 210	COCHRAN	GA	31014	MORRIS GYMNASIUM	Split Ownership	Non-Lead	Cast Iron		
	158 COLLEGE ST	BLDG 220	COCHRAN	GA	31014	GEORGIA HALL	Split Ownership	Non-Lead	Copper		
	COLLEGE ST	BLDG 214	COCHRAN	GA	31014	POOL & TENNIS	Split Ownership	Non-Lead	Other		
	218 SE 2ND ST	BLDG 60	COCHRAN	GA	31014	HARRIS DORMITORY	Split Ownership	Non-Lead	Other		
	SE 2ND ST	BLDG 70	COCHRAN	GA	31014	TALMADGE DORMITORY	Split Ownership	Non-Lead	Ductile Iron		
	KNIGHTS FIELD- VAULT		COCHRAN	GA	31014	KNIGHTS FIELD- VAULT	Split Ownership	Non-Lead	PVC	SERVICE LINE >2" (4" DIAMETER)	
	LAKESIDE DR	BLDG 305	COCHRAN	GA	31014	WELLNESS CENTER	Split Ownership	Non-Lead	Other		
	LAKESIDE DR	BLDG 260	COCHRAN	GA	31014	WHIPPLE HALL	Split Ownership	Non-Lead	Other		
	LAKESIDE DR	BLDG 215	COCHRAN	GA	31014	ATHLETIC TRAINING FACILITY	Split Ownership	Non-Lead	Copper		
	LAKESIDE DR	BLDG 300	COCHRAN	GA	31014	MGSU PLANT OPERATIONS	Split Ownership	Non-Lead	Concrete		
	STUCKEY FIELD		COCHRAN	GA	31014	STUCKEY FIELD	Split Ownership	Non-Lead	PVC		



Water System-Owned Portion					Customer-Owned Portion			
<i>Method used to determine Service Line Classification.</i>	<i>Additional information regarding method used to determine service line classification.</i>	<i>If documentation can be provided, service lines installed on or after January 1, 1990 can be considered non-lead based on the effective dates of the Federal/State lead ban.</i>	<i>Exact date or year service line was installed or replaced.</i>	<i>Presence of a gooseneck, pigtail, or other type of lead connector? Water Systems must replace any lead gooseneck, pigtail, or connector it owns when encountered during planned or unplanned water infrastructure work.</i>	<i>The service line classification table can be referenced under the "Classifying SLs" worksheet.</i>	<i>If known, select the specific service line material from the dropdown bar</i>	<i>Additional information water systems want to note pertaining to the service line material.</i>	<i>Method used to determine Service Line Classification.</i>
Water System-Owned Portion Basis of Material Classification Reference Column J *Required*	Water System-Owned Portion Basis of Material Classification Additional Information	Water System-Owned Portion Service Line Installation Date *Required*	Water System-Owned Portion Exact Service Line Installation Date	Presence of Lead Connector	Customer-Owned Portion Service Line Material Classification *Required*	Customer-Owned Portion Specific Service Line Material	Customer-Owned Portion Service Line Material Additional Information	Customer-Owned Portion Basis of Material Classification Reference Column R *Required*
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	PVC		Visual Inspection
Visual Inspection		Unknown			Non-Lead	PVC		Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		Visual Inspection
Visual Inspection		Unknown			(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	Ductile Iron		Visual Inspection
Visual Inspection		Unknown			(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		Visual Inspection
Visual Inspection		Unknown			(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron	SERVICE LINE >2" (3" DIAMETER)	Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	PVC		Visual Inspection
Visual Inspection		Unknown			Non-Lead	Copper		Visual Inspection
Visual Inspection		Unknown			Non-Lead	Copper		Visual Inspection
Visual Inspection		Unknown			(GNRR) Galvanized Not Requiring Replacement - Non-Lead	Ductile Iron		Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	Cast Iron		Visual Inspection
Visual Inspection		Unknown			Non-Lead	Copper		Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	Ductile Iron		Historical Documentation
Visual Inspection		Unknown			Non-Lead	PVC	SERVICE LINE >2" (3" DIAMETER)	Visual Inspection
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Historical Documentation	SERVICE LINES RECENTLY INSTALLED	Post 1990			Non-Lead	Other		Historical Documentation
Visual Inspection		Unknown			Non-Lead	Copper		Visual Inspection
Visual Inspection		Unknown			Non-Lead	Copper		Visual Inspection
Visual Inspection		Unknown			Non-Lead	PVC		Visual Inspection

